

## Temporary structure approval standards checklist

Date in	
Examination date	
Correction date	

Name of zone \_\_\_\_\_

Zone code \_\_\_\_\_

Name of building \_\_\_\_\_

Building No. \_\_\_\_\_

Outline of building	Main purpose of use	Structure	Number of floors
	Total floor area	Building area	

## Application of Special Facility (Article 7)

Item 1 (Spectator facility)	Applicable / Not applicable	Area used for such purpose:	Floor(s) used for such purpose:
Item 2 (Exhibition facility)	Applicable / Not applicable	Area used for such purpose:	Floor(s) used for such purpose:
Item 3 (Food & drink selling facility)	Applicable / Not applicable	Area used for such purpose:	Floor(s) used for such purpose:

Temporary structure approval standards (draft)	Remarks	Reference	Exam
--	---------	-----------	------

## Article 3 (Structural calculation)

Chap. 3 Sec. 8 of Enforcement Ordinance / Others		C	
--	--	---	--

## Article 4 (Lavatory)

Effective openings / Ventilation facility		C	
---	--	---	--

## Article 5 (Lavatory)

Sewerage / Human-waste septic tank / Others		T	
---	--	---	--

## Article 6 (Interior of fire hazard rooms etc.)

Finish: walls (fireproof / quasi-fireproof), ceilings (fireproof / quasi-fireproof)		C	
Zoning by effective drop walls etc. Yes		C	

## Article 7 (Interior of special facilities)

Finish of rooms: walls (fireproof / quasi-fireproof / ), ceilings (fireproof / quasi-fireproof / fire-retardant )		C	
Finish of passages: walls (fireproof / quasi-fireproof), ceilings (fireproof / quasi-fireproof/ fire-retardant)		C	

## Article 8 (Floors used for main purpose above)

Ground floor (evacuation floor) / floor directly above evacuation floor / floor directly below evacuation floor		T	
---	--	---	--

## Article 9 (Front open areas)

Conformance (depth:    m; width:    m) [Enter lower limit values below.] / other		T	
Depth: [ <200m]    3 m [200 m <sup>2</sup> 500 m <sup>2</sup> ]    4 m [500 m <sup>2</sup> ]    4.5 m    Width: width of major exits    m × 2    m			

## Article 10 (Side open areas)

Conformance (width:    m) [Enter lower limit values below.] / relaxation of Article 15 / other		T	
(Floor area    m <sup>2</sup> - 500) / 10 × 0.025 m + 2 m    m (max value: 4 m)			

## Article 11 (Exits of exhibition rooms in exhibition facilities)

Conformance (No. of exits:    2; width of exits:    m    1.5 m) / other		T	
Is it possible to keep doors open?:    Yes		T	

## Article 12 (Passages in exhibition and food &amp; drink selling facilities)

Conformance/middle passages    m    2.5 m / other passages    m    1.8 m) / other		T	
Is there access to effective emergency exits?: Yes		T	

## Article 13 (Stairways in exhibition and food &amp; drink selling facilities)

Conformance (No. of stairways going directly to the ground floor:    2 (1, in case of 100 m <sup>2</sup> or less); width of such stairways:    m    1.5 m; rise:    cm    18 cm; tread:    cm    26 cm) / other		C	
---	--	---	--

## Article 14 (Outside exits in exhibition and food &amp; drink selling facilities)

Conformance (Number of exits:    2; width of exits:    m    1.5m) / other		T	
Is it possible to keep doors open?:    Yes		T	

## Articles 16 and 17 (mutatis mutandis application of prefectural ordinances regarding spectator and exhibition facilities)

Article 16 (Spectating facilities)    applicable (shown in attachement) / not applicable		C	
Article 17 (Exhibition facilities)    applicable(shown in attachment) / not applicable		C	

## Article 18 (Relaxation of regulations)

Application of relaxation: applicable (method:    ) / not applicable		T	
--	--	---	--

\* Circle the appropriate items as a rule. If figures are required, enter the lowest limit value.

\* If "other" applies give details under "Remarks."

\* Cross out with oblique lines any articles unrelated to building in question.

\* Do not fill in "Exam" columns.

\* "T" and "C" under "Reference" indicate reference to drawings accompanying "Temporary Building Permit Application" at "Plan Change Confirmation Application," respectively.